

## CONTRACTOR VERIFIED REPORT

This form shall be completed by each contractor having a contract with the owner, in accordance with California Code of Regulations, Title 24, Part 1, Sections 4-343 or 4-220. The completed form shall be submitted to the Design Professional in General-Responsible Charge, DSA, the project inspector and the school board.

School District/Owner: Beverly Hills Unified School District		DSA File #: 19 - 14
Project Name/School: Horace Mann ES 2-story CR Bldg., subt. Pkg.		DSA App. #: 03 - 115036
Date of Report: <u>1 Sept. 2017</u>	Number of Attached Pages: <u>1</u> (If none, enter zero.)	DSA 152 Card #(s): #SW, #01_Bldg. B
Note that <b>DSA-approved</b> construction documents, referred to below, are those portions of the construction documents, duly approved by DSA, that contain information related to and affecting the Structural Safety, Fire/Life Safety, and Accessibility portions of the project.		List all inspection card numbers for which this verified report applies.
<b>COMPLETE SECTIONS 1, 2, 3 &amp; 4 AND PROVIDE ALL REQUIRED DOCUMENTATION</b>		
<b>1. CONTRACTOR INFORMATION</b> (Enter name and check applicable box.)		
Name of Contractor (Company/Firm) Submitting this Report: ProWest, PCM, Inc.		
<input checked="" type="checkbox"/>	Operating as general contractor responsible for all work shown in the DSA-approved construction documents.	
<input type="checkbox"/>	Operating as contractor responsible for part of the work shown in the DSA-approved construction documents. (Describe scope of work in the contract. Attach additional pages, using form DSA 211, if necessary):	
<b>2. REASON FOR FILING THIS VERIFIED REPORT</b> (Check applicable box.)		
<input checked="" type="checkbox"/>	Final Verified Report: Construction of all work shown in the DSA-approved construction documents that is part of my contract is complete.	
<input type="checkbox"/>	Termination of contract prior to completion of all work in the contract (Provide last date of work):	
<input type="checkbox"/>	DSA Request dated:	
<b>3. DEFERRED SUBMITTALS</b> (Check applicable box.)		
<input type="checkbox"/>	This project does not require deferred submittals within the scope of my contract.	
<input checked="" type="checkbox"/>	All deferred submittals within the scope of my contract are approved by DSA.	
<input type="checkbox"/>	The following deferred submittals, within the scope of my contract, are <b>not approved</b> by DSA (Provide list. Attach additional pages, using form DSA 211, if necessary.):	
<b>4. DEVIATIONS AS OF THE DATE OF THIS REPORT</b> (Check applicable box.)		
<input type="checkbox"/>	There are no outstanding or unresolved deviation notices pertinent to my contract and related to work shown in the DSA-approved construction documents.	
<input checked="" type="checkbox"/>	There are unresolved deviation notices pertinent to my contract and related to work shown in the DSA-approved construction documents. They are documented by the following form DSA 154 Notice of Deviations (provide list of DSA 154 Notice numbers and attach copies).	
<input checked="" type="checkbox"/>	There is work pertinent to my contract that is not completed in compliance with the DSA-approved construction documents. (Briefly describe. Attach additional pages, using form DSA 211, if necessary.)	

I attest that based on my own personal knowledge (as defined in California Code of Regulations, Title 24, Part 1, Sections 4-336 and 4-214) that, except as marked in Sections 3 and 4, as of the date of this report, the work has been performed and materials have been used and installed, in every material respect, in compliance with the DSA-approved construction documents. I declare under penalty of perjury that I prepared this report and that all statements are true.

Contractor Signature: \_\_\_\_\_

Date: 9/1/17

Print Name: David L. Saacks

Contractor's License No.: 706619

Submit completed form to the DSA Regional Office with construction oversight authority for the project.

## NOTICE OF DEVIATIONS/RESOLUTION OF DEVIATIONS

This form shall be completed by the Project Inspector, in accordance with California Code of Regulations, Title 24, Part 1, Section 4-342 (b).6. The Project Inspector shall provide a copy to the contractor, the architect/engineer and DSA.

School District/Owner: <b>Beverly Hills Unifkied School District</b>		DSA File #: <b>19 - 14</b>
Project Name/School: <b>Horace Mann, New Classroom Building</b>		DSA App. #: <b>03 -115036</b>
From: (Name of Project Inspector) <b>A. Michael Barbera</b>	DSA Certification #: <b>#3430</b>	DSA 152 Card #(s): <b>#01, Building B</b>
To: (Name of Contractor) <b>Prowest</b>		
Notice #: <b>39</b>	Date of Notice: <b>10-10-16</b>	(List all inspection card numbers for which this notice applies.)

Note that **DSA approved** construction documents, referred to below, are those portions of the construction documents, duly approved by the DSA, that contain information related to and affecting the Structural Safety, Fire/Life Safety and Accessibility portions of the project.

### 1. REASON FOR NOTICE (Check applicable box.)



**Deviations** from DSA approved construction documents. (Complete Section 2.)



**Resolution** of previously notified deviations. (Complete Sections 2 and 3.)


### 2. NOTIFICATION OF DEVIATIONS

The following deviations have been brought to the contractor's attention and have not been corrected. Written notice is now being given and the deviations must be corrected prior to Project Inspector acceptance of the affected work. When all deviations have been corrected, the affected work must be re-inspected and Section 3 of this form completed by the Project Inspector.

Description of Deviations	Plan Reference/ Specification Section
<p>Remove projectioning hazard at lower level parking Path of travel. No installations to project into path of travel &gt;4 inches above 27Inches and lower and 80Inches. Remove or remount hazards.</p> <p>Item in question was a wall-mounted Fire Extinguisher Cabinet in the Accessible Route. This was relocated as well as a wall mounted Electrical device on 7/27/17.</p> <p>This issue is now resolved, and the Accessible Route has no non-compliant projections.</p>	

### 3. PROJECT INSPECTOR VERIFICATION OF RESOLUTION OF DEVIATIONS

All deviations noted above have been corrected and the affected work is in compliance with the DSA approved construction documents.

NAME OF PROJECT INSPECTOR: <b>A. Michael Barbera</b>	SIGNATURE: 	DATE: <b>08-01-17</b>
---	--	--------------------------

Submit completed form electronically to the DSA Regional Office with construction oversight authority for the project (see DSA Procedure PR 13-01).



## NOTICE OF DEVIATIONS/RESOLUTION OF DEVIATIONS

This form shall be completed by the Project Inspector, in accordance with California Code of Regulations, Title 24, Part 1, Section 4-342 (b).6. The Project Inspector shall provide a copy to the contractor, the architect/engineer and DSA.

School District/Owner: <b>Beverly Hills Unifkied School District</b>		DSA File #: <b>19 -14</b>
Project Name/School: <b>Horace Mann, New Classroom Building</b>		DSA App. #: <b>03 -115036</b>
From: (Name of Project Inspector) <b>A. Michael Barbera</b>	DSA Certification #: <b>#3430</b>	DSA 152 Card #(s): <b>#01, Building B</b>  (List all inspection card numbers for which this notice applies.)
To: (Name of Contractor) <b>Prowest</b>		
Notice #: <b>41</b>	Date of Notice: <b>10-10-16</b>	

Note that **DSA approved** construction documents, referred to below, are those portions of the construction documents, duly approved by the DSA, that contain information related to and affecting the Structural Safety, Fire/Life Safety and Accessibility portions of the project.

### 1. REASON FOR NOTICE (Check applicable box.)



**Deviations** from DSA approved construction documents. (Complete Section 2.)



**Resolution** of previously notified deviations. (Complete Sections 2 and 3.)

### 2. NOTIFICATION OF DEVIATIONS

The following deviations have been brought to the contractor's attention and have not been corrected. Written notice is now being given and the deviations must be corrected prior to Project Inspector acceptance of the affected work. When all deviations have been corrected, the affected work must be re-inspected and Section 3 of this form completed by the Project Inspector.

Description of Deviations	Plan Reference/ Specification Section
<p>Guardrail gaps &gt;4Inches to be closed where adjacent grade more than 30 ".</p> <p>On January 4, 2018, all guardrail gaps &gt; 4" were addressed to meet code requirements.</p> <p>This deviation is hereby resolved.</p>	<p>Detail 21/A5.11 and CBC Section 1013.3</p>

### 3. PROJECT INSPECTOR VERIFICATION OF RESOLUTION OF DEVIATIONS

All deviations noted above have been corrected and the affected work is in compliance with the *DSA approved* construction documents.

NAME OF PROJECT INSPECTOR: <b>A. Michael Barbera</b>	SIGNATURE: <b>A. Michael Barbera</b>	Digitally signed by A. Michael Barbera Date: 2018.01.08 13:36:53 -08'00'	DATE: <b>01-08-18</b>
---	---	---	--------------------------

Submit completed form electronically to the DSA Regional Office with construction oversight authority for the project (see DSA Procedure PR 13-01).

## NOTICE OF DEVIATIONS/RESOLUTION OF DEVIATIONS

This form shall be completed by the Project Inspector, in accordance with California Code of Regulations, Title 24, Part 1, Section 4-342 (b).6. The Project Inspector shall provide a copy to the contractor, the architect/engineer and DSA.

School District/Owner: <b>Beverly Hills Unifkied School District</b>		DSA File #: <b>19 -14</b>
Project Name/School: <b>Horace Mann, New Classroom Building</b>		DSA App. #: <b>03 -115036</b>
From: (Name of Project Inspector) <b>A. Michael Barbera</b>	DSA Certification #: <b>3430</b>	DSA 152 Card #(s): <b>#01, Building B</b>
To: (Name of Contractor) <b>Prowest</b>		
Notice #: <b>46</b>	Date of Notice: <b>12-08-16</b>	(List all inspection card numbers for which this notice applies.)

Note that **DSA approved** construction documents, referred to below, are those portions of the construction documents, duly approved by the DSA, that contain information related to and affecting the Structural Safety, Fire/Life Safety and Accessibility portions of the project.

### 1. REASON FOR NOTICE (Check applicable box.)



**Deviations** from DSA approved construction documents. (Complete Section 2.)



**Resolution** of previously notified deviations. (Complete Sections 2 and 3.)

### 2. NOTIFICATION OF DEVIATIONS

The following deviations have been brought to the contractor's attention and have not been corrected. Written notice is now being given and the deviations must be corrected prior to Project Inspector acceptance of the affected work. When all deviations have been corrected, the affected work must be re-inspected and Section 3 of this form completed by the Project Inspector.

Description of Deviations	Plan Reference/ Specification Section
<b>Complete lower level exit and directional signage.</b>  <b>Resolution: All lower level exit and directional signs have been installed per DSA Approved Documents.</b>	<b>21, 23/A10.1</b>

### 3. PROJECT INSPECTOR VERIFICATION OF RESOLUTION OF DEVIATIONS

All deviations noted above have been corrected and the affected work is in compliance with the *DSA approved* construction documents.

NAME OF PROJECT INSPECTOR: <b>A. Michael Barbera</b>	SIGNATURE: <b>A. Michael Barbera</b> <small>Digitally signed by A. Michael Barbera Date: 2017.09.01 12:58:58 -0700</small>	DATE: <b>09-01-17</b>
---	--	--------------------------

**Submit completed form electronically to the DSA Regional Office with construction oversight authority for the project (see DSA Procedure PR 13-01).**



# NOTICE OF DEVIATIONS/RESOLUTION OF DEVIATIONS

This form shall be completed by the Project Inspector, in accordance with California Code of Regulations, Title 24, Part 1, Section 4-342 (b).6. The Project Inspector shall provide a copy to the contractor, the architect/engineer and DSA.

School District/Owner: <b>Beverly Hills Unifkied School District</b>		DSA File #: <b>19 -14</b>
Project Name/School: <b>Horace Mann, New Classroom Building</b>		DSA App. #: <b>03 -115036</b>
<b>From:</b> (Name of Project Inspector) <b>A. Michael Barbera</b>		<b>DSA Certification #:</b> <b>#3430</b>  <b>DSA 152 Card #(s):</b> <b>#01, Building B</b>  <i>(List all inspection card numbers for which this notice applies.)</i>
<b>To:</b> (Name of Contractor) <b>Prowest</b>		
<b>Notice #:</b> <b>43</b>	<b>Date of Notice:</b> <b>10-10-16</b>	

Note that **DSA approved** construction documents, referred to below, are those portions of the construction documents, duly approved by the DSA, that contain information related to and affecting the Structural Safety, Fire/Life Safety and Accessibility portions of the project.

## 1. REASON FOR NOTICE (Check applicable box.)



**Deviations** from DSA approved construction documents. (Complete Section 2.)



**Resolution** of previously notified deviations. (Complete Sections 2 and 3.)

## 2. NOTIFICATION OF DEVIATIONS

The following deviations have been brought to the contractor's attention and have not been corrected. Written notice is now being given and the deviations must be corrected prior to Project Inspector acceptance of the affected work. When all deviations have been corrected, the affected work must be re-inspected and Section 3 of this form completed by the Project Inspector.

Description of Deviations	Plan Reference/ Specification Section
<b>Tripping hazard at top of B009 stairs. Relocate handrails to eliminate hazard.</b>  On 1/4/17, the upper portion of handrails and guardrail were modified to resolve the trip hazard identified by previous Project Inspector. All ADA clearances and handrail heights were maintained to comply with CBC and the approved DSA documents.  This hereby resolves this deviation.	<b>3/AB5.13</b>

## 3. PROJECT INSPECTOR VERIFICATION OF RESOLUTION OF DEVIATIONS

All deviations noted above have been corrected and the affected work is in compliance with the *DSA approved* construction documents.

NAME OF PROJECT INSPECTOR: <b>A. Michael Barbera</b>	SIGNATURE: <b>A. Michael Barbera</b>	Digitally signed by A. Michael Barbera Date: 2018.01.08 13:43:28 -08'00'	DATE: <b>01-08-18</b>
---	---	---	--------------------------

Submit completed form electronically to the DSA Regional Office with construction oversight authority for the project (see DSA Procedure PR 13-01).





154

## NOTICE OF DEVIATIONS/RESOLUTION OF DEVIATIONS

This form shall be completed by the Project Inspector, in accordance with California Code of Regulations, Title 24, Part 1, Section 4-342 (b).6. The Project Inspector shall provide a copy to the contractor, the architect/engineer and DSA.

School District/Owner: <b>Beverly Hills Unifkied School District</b>		DSA File #: <b>19 - 14</b>
Project Name/School: <b>Horace Mann, New Classroom Building</b>		DSA App. #: <b>03 -115036</b>
From: (Name of Project Inspector) <b>A. Michael Barbera</b>		DSA 152 Card #(s): <b>#01, Building B</b>
To: (Name of Contractor) <b>Prowest</b>		
Notice #: <b>48</b>	Date of Notice: <b>12-08-16</b>	(List all inspection card numbers for which this notice applies.)

Note that **DSA approved** construction documents, referred to below, are those portions of the construction documents, duly approved by the DSA, that contain information related to and affecting the Structural Safety, Fire/Life Safety and Accessibility portions of the project.

### 1. REASON FOR NOTICE (Check applicable box.)



Deviations from DSA approved construction documents. (Complete Section 2.)



Resolution of previously notified deviations. (Complete Sections 2 and 3.)


### 2. NOTIFICATION OF DEVIATIONS

The following deviations have been brought to the contractor's attention and have not been corrected. Written notice is now being given and the deviations must be corrected prior to Project Inspector acceptance of the affected work. When all deviations have been corrected, the affected work must be re-inspected and Section 3 of this form completed by the Project Inspector.

Description of Deviations	Plan Reference/ Specification Section
<p>Provide electrical bonding to MSB yard metal fencing.</p> <p>Resolution: 8/3/17: All metal fences were bonded to main Ground Rod, as required as noted in Detail 1/EB-605. Meggar test was also performed to check continuity: Results were less than .1OHMS. This issue is resolved.</p>	<b>1/EB-605 Grounding Details</b>

### 3. PROJECT INSPECTOR VERIFICATION OF RESOLUTION OF DEVIATIONS

All deviations noted above have been corrected and the affected work is in compliance with the DSA approved construction documents.

NAME OF PROJECT INSPECTOR: <b>A. Michael Barbera</b>	SIGNATURE: 	DATE: <b>08-03-17</b>
---	--	--------------------------

Submit completed form electronically to the DSA Regional Office with construction oversight authority for the project (see DSA Procedure PR 13-01).



# NOTICE OF DEVIATIONS/RESOLUTION OF DEVIATIONS

This form shall be completed by the Project Inspector, in accordance with California Code of Regulations, Title 24, Part 1, Section 4-342 (b).6. The Project Inspector shall provide a copy to the contractor, the architect/engineer and DSA.

School District/Owner: <b>Beverly Hills Unified School District</b>		DSA File #: <b>19 -14</b>
Project Name/School: <b>Horace Mann, New Classroom Building</b>		DSA App. #: <b>03 -115036</b>
<b>From:</b> (Name of Project Inspector) <b>A. Michael Barbera</b>		<b>DSA Certification #:</b> <b>3430</b>  <b>DSA 152 Card #(s):</b> <b>#01,</b>  <i>(List all inspection card numbers for which this notice applies.)</i>
<b>To:</b> (Name of Contractor) <b>Prowest</b>		
<b>Notice #:</b> <b>50</b>	<b>Date of Notice:</b> <b>04-17-17</b>	

Note that **DSA approved** construction documents, referred to below, are those portions of the construction documents, duly approved by the DSA, that contain information related to and affecting the Structural Safety, Fire/Life Safety and Accessibility portions of the project.

## 1. REASON FOR NOTICE (Check applicable box.)



**Deviations** from DSA approved construction documents. (Complete Section 2.)



**Resolution** of previously notified deviations. (Complete Sections 2 and 3.)

## 2. NOTIFICATION OF DEVIATIONS

The following deviations have been brought to the contractor's attention and have not been corrected. Written notice is now being given and the deviations must be corrected prior to Project Inspector acceptance of the affected work. When all deviations have been corrected, the affected work must be re-inspected and Section 3 of this form completed by the Project Inspector.

Description of Deviations	Plan Reference/ Specification Section
<p><b>Complete fire safing at plumbing and electrical penetrations thru 1st floor structural deck with approved UL safing system.</b></p> <p><b>Resolution:</b> Fire Safing at remaining plumbing and electrical penetrations through 1st floor structural deck, were completed with approved UL safing systems.</p>	

## 3. PROJECT INSPECTOR VERIFICATION OF RESOLUTION OF DEVIATIONS

All deviations noted above have been corrected and the affected work is in compliance with the *DSA approved* construction documents.

NAME OF PROJECT INSPECTOR: <b>A. Michael Barbera</b>	SIGNATURE: <b>A. Michael Barbera</b> <small>Digitally signed by A. Michael Barbera Date: 2017.09.01 13:41:08 -0700</small>	DATE: <b>09-01-17</b>
---	---	--------------------------

**Submit completed form electronically to the DSA Regional Office with construction oversight authority for the project (see DSA Procedure PR 13-01).**

## NOTICE OF DEVIATIONS/RESOLUTION OF DEVIATIONS

This form shall be completed by the Project Inspector, in accordance with California Code of Regulations, Title 24, Part 1, Section 4-342 (b).6. The Project Inspector shall provide a copy to the contractor, the architect/engineer and DSA.

School District/Owner: <b>Beverly Hills Unified School District</b>		DSA File #: <b>19 - 14</b>
Project Name/School: <b>Horace Mann, New Classroom Building</b>		DSA App. #: <b>03 -115036</b>
From: (Name of Project Inspector) <b>A. Michael Barbera</b>	DSA Certification #: <b>3430</b>	DSA 152 Card #(s): <b>#01,</b>  (List all inspection card numbers for which this notice applies.)
To: (Name of Contractor) <b>Prowest</b>		
Notice #: <b>51</b>	Date of Notice: <b>04-17-17</b>	

Note that **DSA approved** construction documents, referred to below, are those portions of the construction documents, duly approved by the DSA, that contain information related to and affecting the Structural Safety, Fire/Life Safety and Accessibility portions of the project.

### 1. REASON FOR NOTICE (Check applicable box.)



**Deviations** from DSA approved construction documents. (Complete Section 2.)



**Resolution** of previously notified deviations. (Complete Sections 2 and 3.)

### 2. NOTIFICATION OF DEVIATIONS

The following deviations have been brought to the contractor's attention and have not been corrected. Written notice is now being given and the deviations must be corrected prior to Project Inspector acceptance of the affected work. When all deviations have been corrected, the affected work must be re-inspected and Section 3 of this form completed by the Project Inspector.

Description of Deviations	Plan Reference/ Specification Section
<p><b>Provide approved anchorage for fire extinguisher cabinets where mounted to concrete walls at lower level parking and stairwell.</b></p> <p><b>Approved anchorage was provided by AOR at the subject Area and all were re-inspected and found to comply.</b></p>	

### 3. PROJECT INSPECTOR VERIFICATION OF RESOLUTION OF DEVIATIONS

All deviations noted above have been corrected and the affected work is in compliance with the *DSA approved* construction documents.

NAME OF PROJECT INSPECTOR: <b>A. Michael Barbera</b>	SIGNATURE: <b>A. Michael Barbera</b> <small>Digitally signed by A. Michael Barbera Date: 2017.08.17 20:55:17 -0700</small>	DATE: <b>08-17-17</b>
---	--	--------------------------

Submit completed form electronically to the DSA Regional Office with construction oversight authority for the project (see DSA Procedure PR 13-01).



## PROJECT INSPECTOR SEMI-MONTHLY REPORT

This form shall be completed by the Project Inspector, in accordance with California Code of Regulations, Title 24, Part 1, Section 4-337. Use DSA 155 Instructions as a guideline for completion and distribution of this form.

School District/Owner: <b>Beverly Hills USD</b>		DSA File #: <b>19 - 14</b>
Project Name/School: <b>New Classroom Bldg, Horrace Mann School</b>		DSA App. #: <b>03 - 115036</b>
<b>From:</b> (Name of Project Inspector) Name: <b>A. Michael Barbera</b>		DSA Certification #: <b>3430</b>  DSA 152 Card #(s): <b>SW #1</b>  <i>(List all inspection card numbers for which this report applies.)</i>
Report #: <b>81</b>	Date of Report: <b>03-16-18</b>	
Number of attached pages: (If none, enter "0.") <b>0</b>		
<b>REPORTING PERIOD DATES</b>	From: <b>03-01-18</b>	To: <b>03-15-18</b>
Construction project is estimated to be <b>99</b> % complete at this time.		
Note that <b>DSA approved</b> construction documents, referred to below, are those portions of the construction documents, duly approved by the DSA, that contain information related to and affecting the Structural Safety, Fire/Life Safety and Accessibility portions of the project		

<p><b>PROVIDE THE FOLLOWING INFORMATION FOR THE REPORTING TIME PERIOD: (Continues on Pages 2 &amp; 3)</b></p> <p><b>STATUS OF CONSTRUCTION WORK:</b> (Provide a brief description of work in progress, including a listing of fabrication work performed off-site. Attach additional pages if necessary.)</p> <p><b>*Michael Barbera #3430 replaced Zach Abrego, #4181 as Project Inspector officially as of 7/6/17, the date of the DSA 5PI approval.</b></p> <p>The remaining activities are as follows:</p> <p>DSA 152 Bldg.Card 01:          -Corrections to HVAC Gas flue extensions were observed by P.I. during fire alarm testing in January. MEOR concurred and provided clarification regarding the height of flues at identified units. The replacement flue extensions are noted on the DSA Approved Plans. This corrective work has not been scheduled as of this report.</p> <p>DSA 152 SW Card: :          Remaining site work per DSA Approved plans is generally the completion of ADA ramp up new Playfield. This involves concrete footings, ramp walls, Hand and Guard Rails. Also, Fire Lane, and site lighting concrete bollard footings, and associated electrical conduit, etc. This work is being planned to coincide with the remaining Site Work project, A.#03-117920. Preparations continue via site visits and meetings with the AOR to confirm and finalize scope.</p>
---

## PROJECT INSPECTOR SEMI-MONTHLY REPORT

Report #: 81	Date of Report: 03-16-18	DSA App. #: 03 - 115036
--------------	--------------------------	-------------------------

**PROVIDE THE FOLLOWING INFORMATION FOR THE REPORTING TIME PERIOD (Continued from Page 1)**
**PROBLEMS OR NON-COMPLYING CONDITIONS: (Complete Sections A and B.)**

<b>A</b>	<b>DEVIATIONS RELATED TO THE WORK SHOWN IN THE DSA APPROVED CONSTRUCTION DOCUMENTS</b> (Check the applicable boxes and provide the notice numbers from the form DSA 154 used to notice the deviations/resolutions.)	
<input type="checkbox"/>	There are unresolved deviations for this reporting period.	<b>Form DSA 154 Notice Numbers</b>
<input type="checkbox"/>	There are resolved deviations for this reporting period.	
<input checked="" type="checkbox"/>	There are no unresolved/resolved deviations for this reporting period.	<b>N/A</b>
<b>B</b>	<b>DEVIATIONS RELATED TO OTHER WORK SHOWN IN THE CONSTRUCTION DOCUMENTS</b> (Check applicable boxes and provide required information.)	
<input type="checkbox"/>	There are no unresolved/resolved deviations for this reporting period.	
<input type="checkbox"/>	There are <b>unresolved deviations</b> for this reporting period.	
<input type="checkbox"/>	There are <b>resolved deviations</b> for this reporting period. (Provide brief description of resolved deviations and how resolved. Attach additional pages if needed.)	



**PROJECT INSPECTOR SEMI-MONTHLY REPORT**

Report #: 81

Date of Report: 03-16-18

DSA App. #: 03 - 115036

**PROVIDE THE FOLLOWING INFORMATION FOR THE REPORTING TIME PERIOD (Continued from Page 1)****DSA FIELD TRIP NOTES ISSUED DURING THIS REPORTING PERIOD***(Check the applicable boxes and provide the required information.)*☒ There were no DSA Field Trip Notes issued.☐ There were DSA Field Trip Notes issued. *(Complete below table.)***Dates Issued: Does Field Trip Note require action by the Architect?**☐ Yes ☐ No☐ Yes ☐ No☐ Yes ☐ No☐ Yes ☐ No☐ Yes ☐ No☐ Yes ☐ No**QUESTIONS OR UNUSUAL CONDITIONS: (List any encountered. Attach additional page if needed.)**

Unresolved Deviations- None.

Resolved Deviations- 1,2,3,4,5,6,7,8, 9,10,11,12,13,14,15,16,17,18,19, 20,21,22,23,24, 25,26,27,28,29,30, 31, 32, 33, 34, 35, 36,37, 38, 39, 40, 41, 42,43, 46, 44,45, 47, 48, 49, 50, 51. \*9, 10, 24 from P.I. #4483.

Unresolved FTN- FTN #30, Item 1: Requires Terminating P.I. to revise DSA6PI to include D.N. #9,10,24.

Resolved FTN-FTN #2/1, # 3/1, #4/1,2,3,4,5 and #6/16/5

**INSTRUCTIONS RECEIVED FROM THE ARCHITECT OR REGISTERED ENGINEER:***(List any. Attach additional page if needed.)***OFFICIAL SITE VISITORS: (List any and whom they represent. May include, architects, registered engineers, laboratory personnel, special inspectors, school district representatives, DSA field representative, etc. Attach additional page if needed.)**

None.

**Submit completed form electronically to the DSA Regional Office with construction oversight authority for the project (see DSA Procedure PR 13-01).**