

11-09-2020

Mr. Kevin Emenaker
Executive Director of Administrative Services
Alvord Unified School District
9 KPC Parkway
Corona, California 92879

Reference: Notice of Final Completion

Dear Mr. Emenaker ;

Please take notice of Final Completion as of the date stated above of the **90020003 Alvord PH II ESA** contract that was set forth between the Alvord USD and Climatec, LLC.

This correspondence confirms the Final Completion of the scope of work at the following locations:

SCOPE OF SERVICES LOCATIONS

Per matrix attached on page 2

Climatec, LLC. appreciates the opportunity to partner with the Alvord USD through the implementation and execution of the scope of work as stated in the agreement, Project Number 90020003.

Please sign and date below to acknowledge completion of the Scope of Work at the locations listed above, and return to the Project Manager.

Sincerely,
Climatec, LLC.

Name of Signator, Title

Print Name

Date

Alvord 03 ESA Scope of Services

School	Controls	Lighting	HVAC	Solar
Alvord High	(4) Lighting Time Clocks	X		
Arizona Middle	(7) Lighting Time Clocks	X		
Arlanza Middle		X		
Collett Elementary		X	(2) Split Systems	
Facilities (MOT)		X		
Foothill Elementary		X	(15) Split Systems	
Hillcrest High	Replaced Carrier w/Pelican	X		
La Granada Elementary	(5) Lighting Time Clocks	X	(7) Wall-Mounted Heat Pumps	
Lake Hills Elementary	Replaced Carrier w/Pelican	X		
Loma Vista Middle	(7) Lighting Time Clocks	X		
McAuliffe Elementary	(4) Lighting Time Clocks	X		
Myra Linn Elementary	(6) Lighting Time Clocks	X		
Orrenmaa Elementary		X	Air-Cooled Chiller	
Phillip Stokoe Elementary	(9) Lighting Time Clocks	X		
Promenade Elementary	(3) Lighting Time Clocks	X		
Rosemary Kennedy Elementary	Replaced Carrier w/Pelican	X	(6) Roof-Mounted Package Units; (1) Split System	
Terrace Elementary		x		
Twinhill Elementary	Replaced Existing w/Pelican Controls	X	(13) Split System; (2) Roof-Mounted Package Units	
Valley View Elementary	(6) Lighting Time Clocks	X		
Villegas Middle	Replaced Carrier w/ Pelican	X		Solar Photovoltaic – Parking Canopy (203.6 kW DC)
Wells Middle	(5) Lighting Time Clocks	X		